



Element Materials Technology - Fort Wayne
 328 Ley Rd.
 Fort Wayne, IN 46825
 TEL: (260) 424-1622 FAX: (260) 424-9124
 Website: www.element.com

Analytical Report

(continuous)

WO#: 21050821

Date Reported 5/27/2021

CLIENT: Town of Andrews

Lab Order: 21050821

Project: PWSID IN5235001 VOC

Lab ID: 21050821-001

Collection Date: 5/10/2021 8:24:00 AM

Client Sample ID: no 1 POE Well no 2

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
VOCS IN DRINKING WATER						
		E524.2				Analyst: SDF
Benzene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Carbon tetrachloride	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Chlorobenzene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,2-Dichlorobenzene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,4-Dichlorobenzene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,2-Dichloroethane	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,1-Dichloroethene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
cis-1,2-Dichloroethene	3.9	0.5		µg/L	1	5/13/2021 4:14:00 PM
trans-1,2-Dichloroethene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Methylene chloride	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,2-Dichloropropane	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Ethylbenzene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Styrene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Tetrachloroethene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Toluene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,2,4-Trichlorobenzene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,1,1-Trichloroethane	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
1,1,2-Trichloroethane	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Trichloroethene	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Vinyl chloride	0.6	0.5		µg/L	1	5/13/2021 4:14:00 PM
Xylenes, Total	< 0.5	0.5		µg/L	1	5/13/2021 4:14:00 PM
Surr: 1,2-Dichlorobenzene-d4	84.9	70 - 130		%Rec	1	5/13/2021 4:14:00 PM
Surr: Bromofluorobenzene	75.5	70 - 130		%Rec	1	5/13/2021 4:14:00 PM

Qualifiers:	H	Holding times for preparation or analysis exceeded	M	Manual Integration used to determine area response
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PQL	Practical Quantitation Limit	RL	Reporting Detection Limit
	S	Spike Recovery outside accepted recovery limits		